



ఆంధ్ర ప్రదేశ్ రాజ పత్రము

THE ANDHRA PRADESH GAZETTE

PART-II EXTRAORDINARY
PUBLISHED BY AUTHORITY

No. 75]

HYDERABAD, FRIDAY, MAY 28, 2010.

NOTIFICATIONS BY HEADS OF DEPARTMENTS, Etc.

—x—

PUBLIC WORKS NOTIFICATIONS

TRANSMISSION CORPORATION OF ANDHRA PRADESH LIMITED

NOTIFICATION OF 400 kV TRANSMISSION SCHEME.

Lr.No. CE/400 kV/SE(P&MM)/AEE-1/KPPTS/26/2010.

Transmission Corporation of Andhra Pradesh Limited proposes to augment the transmission system for evacuation of power from Krishnapatnam Thermal Power Station (2x800 MW) of APGENCO, with the erection of the following Transmission Line and Bay extensions under “Krishnapatnam Power Transmission Scheme”. The total estimated cost of the scheme is Rs. 510.89 Crore, including an interest during construction of Rs. 58.76 Crore. The Scheme is proposed for completion during the year 2012-2013 and will result in reduction of EHT transmission losses, improvement of voltage profiles & meets the additional load demand in the region and surrounding areas.

- 1) Krishnapatnam TPS - 400 kV Chittoor Quad Double Circuit Line: 187 km;
- 2) Krishnapatnam TPS - 400 kV Manubolu Quad Double Circuit Line: 36 km;
- 3) 2 Nos. 400 kV bay extensions at Chittoor 400 kV Substation;
- 4) 2 Nos. 400 kV bay extensions at Manubolu 400 kV Substation.

In exercise of the powers conferred vide G.O.Ms.No. 115, dated 07.10.2003 of Government of Andhra Pradesh, APTRANSCO or their authorized representatives shall have the powers for placing of the electric supply lines or electric plant for the transmission of electricity or for the purpose of telephonic or telegraphic communications necessary for the proper co-ordination of works that a telegraphic authority possesses under the provision of the Indian Telegraph Act, 1885 (Central Act-13 of 1885).

Any person interested/aggrieved may make representation to the Chief Engineer/Construction /400 kV, APTRANSCO, Vidyut Soudha, Khairatabad, Hyderabad-500 082 within two (2) months from the date of publication of this notification.

Representations received after the due date will not be considered and APTRANSCO will take-up the above works after due date with/without modification as it deems fit after making enquiry, if necessary.

Hyderabad,
15-05-2010.

(Sd/-),
Chief Engineer,
Construction/ 400kV.

—X—